

**ADDENDUM NO. 1  
JANUARY 3, 2025  
FOR  
ROOSEVELT PARK POOL EQUIPMENT UPGRADES  
MINOT PARK DISTRICT  
MINOT, ND  
DECEMBER 2024**



This Addendum No. 1 forms a part of the Project Manual and modifies the original Bidding Documents as noted within this Addendum. All provisions of the Project Manual not in conflict with this Addendum shall remain in full force. Acknowledge receipt of this Addendum on the outside of the bid envelope and in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This addendum consists of two (2) pages and zero (0) attachments.

**GENERAL CLARIFICATIONS**

Mandatory Pre-Bid Meeting Link

- 1) Use the following information to attend the mandatory pre-bid meeting via video conferencing or phone on Monday January 6, 2025 at 1:00 PM CST:

**Microsoft Teams**

[https://teams.microsoft.com/l/meetup-join/19%3ameeting\\_YTQ1MGRhMTctYWYxYy00MDVILWJmYzctNzJjMmRiOGIwYTIj%40thread.v2/0?context=%7b%22Tid%22%3a%22b32addb5-f43d-4c2a-8383-dd63422a2655%22%2c%22Oid%22%3a%2285212bd4-63ee-4238-a8ed-2a26fedc95d8%22%7d](https://teams.microsoft.com/l/meetup-join/19%3ameeting_YTQ1MGRhMTctYWYxYy00MDVILWJmYzctNzJjMmRiOGIwYTIj%40thread.v2/0?context=%7b%22Tid%22%3a%22b32addb5-f43d-4c2a-8383-dd63422a2655%22%2c%22Oid%22%3a%2285212bd4-63ee-4238-a8ed-2a26fedc95d8%22%7d)

Meeting ID: 291 566 541 966

Passcode: 3Fy6k43z

or

**Dial in by phone**

[+1 701-566-0964,595962906#](tel:+17015660964595962906)

Phone conference ID: 595 962 906#

**SPECIFICATIONS**

Division 13 – Special Construction

Section 13 11 01 – Gas Fired Pool Heaters -

- 1) Section 1.03 SUBMITTALS: **Add** the following: “C. PROVIDE ENGINEER WITH SEQUENCE OF

OPERATION AND SYSTEM CONTROL ADJUSTMENTS.”

Section 13 11 25 –Pool Centrifugal Pumps -

- 1) Section 1.07 SUBMITTALS: **Add** the following note, “C. PROVIDE ENGINEER WITH SEQUENCE OF OPERATION AND SYSTEM CONTROL ADJUSTMENTS.”

Section 13 61 13 –Pool Control System General Requirements -

- 1) **Revise** Section 1.02 APPROVED EQUAL(S) to read as follows, “1.05 APPROVED EQUAL(S)”
- 2) **Add** Section 1.06 SUBMITTALS: A. PROVIDE ENGINEER WITH SEQUENCE OF OPERATION AND SYSTEM CONTROL ADJUSTMENTS.

**DRAWINGS**

Sheet P201

- 1) Note #7: **Revise** note to read, “1-1/2” BACKFLOW PREVENTER (BFP-1) FOR POOL MAKE-UP. ROUTE 1-1/2”CW TO POOL AUTOFILL. SEE P301 FOR EXACT LOCATION.

Sheet P301

- 1) Note #9: **Revise** note to read, “AUTOFILL (CLA-VAL CO.) MODEL NO. 100-01A-KC”.
- 2) Note #19: **Revise** note to read, “NEW FILTER DRAIN PUMP (DP-1).”

Sheet P601

- 1) **Revise** PRIOR APPROVAL SCHEDULE to read, “CONTRACTOR SHALL PROVIDE SPECIFIED EQUIPMENT OR ENGINEER PRIOR APPROVED EQUAL PRODUCT. SEE SPECIFICATION SECTION 01 43 25 – PROCUREMENT SUBSTITUTION PROCEDURES FOR MORE INFORMATION.”

**PRIOR APPROVALS**

- 1) None

**ATTACHMENT LIST TO THIS ADDENDUM**

- 1) None

**End of Addendum No. 1**